

NOTE

Sub: Calling quotations towards Servicing & Maintenance / AMC of Sewage Treatment Plant installed at High Court of Bombay at Goa, Porvorim-Goa.

The High Court of Bombay at Goa, Porvorim, Goa, calling quotation towards Comprehensive & Non-Comprehensive AMC of the Sewage Treatment Plant (STP), installed at the High Court Complex.

It is therefore, requested to submit your best quote in sealed envelope towards Comprehensive & Non-Comprehensive AMC of the Sewage Treatment Plant (STP), on or before 05/03/2025, for the period of one year from **01/04/2025 to 31/03/2026**, for the Sewage Treatment Plant (STP).

Any assistant in the above, be please to call on mobile no. 9823018130 (Mr. Hipolito Azavedo).

GENERAL TERMS AND CONDITIONS:-

1. The Sealed Quotations must be superscribed as **"Quotations for Comprehensive & Non-Comprehensive AMC of Sewage Treatment Plant"** and addressed to **the Registrar (Admn.), High Court of Bombay at Goa, Penha-de-Franca, Porvorim, Goa.**
2. The quoted rate shall remain valid for one year i.e. w.e.f. **01/04/2025 to 31/03/2026.**
3. It shall have PAN number, GST Registration number.
4. The dealer should provide the name and mobile number of the person, to be contacted at any time, even beyond office hours. The person should be capable of maintaining and servicing of Sewage Treatment Plant.
5. The dealer will provide uniforms, Aprons, Photo I-Cards and other-Protective gear to ensure proper protection to the appointed person. It will be the responsibility of the dealer to ensure that its entire staff report for duty in proper uniform and also display their identity cards.

6. The Registrar (Admn.), High Court of Bombay at Goa, Porvorim, reserves all rights to reject any offer or terminate the P.O. at any point of time, without assigning any reason.

AMC Requirements:-

- Operation and maintenance of sewage treatment plant.
- Cleaning of Pumps, blowers, Electrical panel, water filters piping and allied accessories.
- To ensure all standby pumps and blowers are in working condition.
- To keep surrounding areas clean.
- Opening and cleaning of sand and carbon filter including nozzle changing and recharge of filter media.
- Cleaning of aeration tanks, clarifier, sludge tanks, replacement of defective pipes.
- Logbook to monitor overall operation of plant on hourly basis.
- To get periodical test report authorized lab and submit to the client. Pollution control board records to maintain as per the statutory requirement.
- The contractor has to ensure that all the parameters are maintained as per the norms of Pollution Control Board at all the times.

sd/-

Place:- Porvorim, Goa.
Date: 24/02/2025.

(D. P. Sañawalekar)
Registrar (Admin.)